

Department of Planning and Budget 2017 Fiscal Impact Statement

1. Bill Number: SB812

House of Origin	<input checked="" type="checkbox"/>	Introduced	<input type="checkbox"/>	Substitute	<input type="checkbox"/>	Engrossed
Second House	<input type="checkbox"/>	In Committee	<input type="checkbox"/>	Substitute	<input type="checkbox"/>	Enrolled

2. Patron: Marsden

3. Committee: General Laws and Technology

4. Title: Board for Asbestos, Lead, and Home Inspectors; home inspections; required statement related to the presence of yellow shaded corrugated stainless steel tubing.

5. Summary: Provides that whenever a home inspector observes the presence of any shade of yellow corrugated stainless steel tubing during a home inspection, his observation must be included in the inspection report along with the following statement: "Manufacturers believe that this product is safer if properly bonded and grounded as required by the manufacturer's installation instructions. Proper bonding and grounding of the product can only be determined by a licensed electrical contractor."

6. Budget Amendment Necessary: No.

7. Fiscal Impact Estimates: No state fiscal impact.

8. Fiscal Implications: It is anticipated that this bill will not result in a fiscal impact to the Department of Professional and Occupational Regulation. The bill amends the Code to provide for a required statement related to yellow shaded corrugated stainless steel tubing observed during a home inspection.

9. Specific Agency or Political Subdivisions Affected: Department of Professional and Occupational Regulation.

10. Technical Amendment Necessary: No.

11. Other Comments: None.