

VIRGINIA ACTS OF ASSEMBLY — CHAPTER

An Act to amend and reenact § 40.1-51.8 of the Code of Virginia, relating to exemptions to the Boiler and Pressure Vessel Safety Act for certain propane gas containers.

[H 1136]

Approved

Be it enacted by the General Assembly of Virginia:**1. That § 40.1-51.8 of the Code of Virginia is amended and reenacted as follows:**

§ 40.1-51.8. Exemptions.

The provisions of this article shall not apply to any of the following:

1. Boilers or unfired pressure vessels owned or operated by the federal government or any agency thereof;

2. Boilers or fired or unfired pressure vessels used in private residences or apartment houses of less than four apartments;

3. Boilers of railroad companies maintained on railborne vehicles or those used to propel waterborne vessels;

4. Hobby or model boilers as defined in § 40.1-51.19:1;

5. Hot water supply boilers, water heaters, and unfired pressure vessels used as hot water supply storage tanks heated by steam or any other indirect means when the following limitations are not exceeded:

a. A heat input of 200,000 British thermal units per hour;

b. A water temperature of 210° Fahrenheit;

c. A water-containing capacity of 120 gallons;

6. Unfired pressure vessels containing air only which are located on vehicles or vessels designed and used primarily for transporting passengers or freight;

7. Unfired pressure vessels containing air only, installed on the right-of-way of railroads and used directly in the operation of trains;

8. Unfired pressure vessels used for containing water under pressure when either of the following are not exceeded:

a. A design pressure of 300 psi; or

b. A design temperature of 210° Fahrenheit;

9. Unfired pressure vessels containing water in combination with air pressure, the compression of which serves only as a cushion, that do not exceed:

a. A design pressure of 300 psi;

b. A design temperature of 210° Fahrenheit; or

c. A water-containing capacity of 120 gallons;

10. Unfired pressure vessels containing air only, providing the volume does not exceed eight cubic feet nor the operating pressure is not greater than 175 pounds;

11. Unfired pressure vessels having an operating pressure not exceeding fifteen pounds with no limitation on size;

12. Pressure vessels that do not exceed:

a. Five cubic feet in volume and 250 pounds per square inch gauge pressure;

b. One and one-half cubic feet in volume and 600 pounds per square inch gauge pressure; and

c. An inside diameter of six inches with no limitations on gauge pressure;

13. Pressure vessels used for transportation or storage of compressed gases when constructed in compliance with the specifications of the United States Department of Transportation and when charged with gas marked, maintained, and periodically requalified for use, as required by appropriate regulations of the United States Department of Transportation; ~~all others shall be used in accordance with Chapter 7 (§ 27-86 et seq.) of Title 27;~~14. *Until July 1, 2013, qualified stationary American Society of Mechanical Engineers (ASME) LP-Gas containers used exclusively in propane service;*

15. Unfired pressure vessels used in and as a part of electric substations owned or operated by an electric utility, provided such electric substation is enclosed, locked, and inaccessible to the public; or

~~16. Coil type hot water boilers without any steam space where water flashes into steam when released through a manually operated nozzle, unless steam is generated within the coil or unless one of the following limitations is exceeded:~~

a. Three-fourths inch diameter tubing or pipe size with no drums or headers attached;

ENROLLED

HB136ER

- 57** b. Nominal water containing capacity not exceeding six gallons; and
- 58** c. Water temperature not exceeding 350° Fahrenheit.